



# SUBMITTAL : ECO-43SSAQB

## 43 Gallon Storage Tank



Job Name :	Location
Purchaser	Engineer
Submitted to	Reference <input type="checkbox"/> Approval <input type="checkbox"/> Construction <input type="checkbox"/>
Unit Designation	Schedule #

Specifications	ECO-43SSAQB
<b>Performance</b>	
Uniform Energy Factor	3.66
Uniform First Hour Rating	69 Gallons
<b>Design</b>	
Nominal Water Storage Volume	43 Gallons
Pressure Relief Valve (Psig & °F )	150 Psig & 210°F
Temperature Sensor	Thermistor
Tank Weight (lbs)	88lbs
Standby Loss in 67°F Ambient	73 Btu/h
<b>Tank Location &amp; Clearances</b>	
Tank Installation location	Indoor
	Exterior if ambient is always above 34°F
Tank Clearance required	2" around Tank
<b>Tank Connection Sizes</b>	
Cold Water Inlet	3/4" NPT
Hot Water Outlet	3/4" NPT
Cold Water to Heat Pump	3/4" NPT
Hot Water Return from Heat Pump	3/4" NPT
Press Relief Valve Discharge Line	3/4"
<b>Pipe Size - Tank to Heat Pump</b>	
Size	1/2" & 1/2"
Max Pipe Length inc	66ft
Max Vertical Separation of	23ft
<b>Certifications</b>	
Safety	ETL & ETLc
Performance	Energy Star
AHRI Certification reference #	TBA
<b>Tank Warranty</b>	
Tank	15 Years
	Limited Lifetime

### Construction

Storage tank shall be constructed from a blend of 316/444 Stainless Steel pressure tested to 300 psi Tank outer shell shall be steel with a baked on powder coating for protection

### Insulation

A minimum of 1 7/8" R12 polystyrene insulation shall be used to insulate the tank to reduce heat loss

### Connections

All connections shall be 3/4" NPT Female type Brass adaptors will be supplied with tank Cold Water Piping from Storage Tank to Heat Pump and return of Hot Water piping from Heat Pump to Tank be 1/2" Copper or PEX. Reducing nipples shall be field supplied and installed

### Controls

The tank shall be supplied with a Temperature sensor installed in a sensor well to control the GS5-45HPC & GS5-45HPC-D Heat Pumps The tank shall be supplied with 2 extra Thermowells located at the same level as the Hot Water input from the GS5 unit and the Cold Water output to the GS5 Thermowells are to be used for Shed and Load signals from Utilities via CTA-2045/JA-13 Control wiring between Tank to GS5-45HPC and GS4-45HPC-D shall require a 2 wire 18AWG shielded wire between the Tank and Heat Pump

### Pressure and Temperature Relief

Tank shall be supplied with ASME certified Pressure and Temperature Relief valve. Settings shall be at 150 Psig for Pressure and 210°F for Temperature

### Mixing Valve

A factory supplied, but field installed Mixing or Anti Scald valve shall be supplied with the Tank Valve connections shall be 3/4" Female NPT Valve shall be field set to ensure delivered water temperature shall be below 120°F to prevent scalding

Job Name	Location
Purchaser	Engineer
Submitted to	Reference <input type="checkbox"/> Approval <input type="checkbox"/> Construction <input type="checkbox"/>
Unit Designation	Schedule #

### ECO-43SSAQB Dimensions

