

## **SUBMITTAL**: **GS4-45HPC Heat Pump Water Heater**



Job Name	Location	
Purchaser	Engineer	
Submitted to	Reference Appr	roval Construction
Unit Designation	Schedule #	

Specifications	GS4-45HPC
Uniform Energy Factor	Dependent on Tank
Uniform First Hour Rating	Dependent on Tank
Recovery rate @ 90°F Temp Rise	20.6 GPH
Nom Heating Capacity (Btu/h)	15,400 Btu/h
Nom Heating Capacity (kw)	4.5kw
Ambient Operating Range	-26 to 114°F
Heating COP @ 80°F Ambient	5.5
Heating COP @ 43°F Ambient	4.2
Heating COP @ 17°F Ambient	2.8
Water Temperature Setting (°F)	145 to 150°F
Refrigerant Type	R744 (CO <sub>2</sub> )
Refrigerant Charge (Oz)	25.4oz (720g)
Power Voltage	208/230v-1Ph-60Hz
Breaker Size	15A
MCA (Amps)	7.2A
Compressor MRC (Amps)	5.0A
Fan Motor MOC/Watts	0.3A / 30W
Pump MOC/Watts	0.6A / 60W
Noise Level (DbA)	37
Weight (lbs)	108lbs

Storage Tank Model #'s	SAN-43SSAQA
	SAN-83SSAQA
	SAN-119GLBK
	ECO-119GLASME
	ECO-200GLBK
	ECO-285GLNST
	ECO-360GLNST
	ECO-455GLNST
	ECO-505GLNST
Piping - Tank to Heat Pump and	back to Tank
Cold & Hot Water pipe size	1/2" & 1/2"
Max Pipe Length including	66ft
Max Vertical Separation of	23ft
Max Incoming Water Pressure	75 Psi
Certifications	
Safety	ETL/ETLc
Energy Star	US & Canada
Residential <b>Warranty</b> - System	3 Years Labor
Heat Pump	10 Years Parts

#### Construction

The Outdoor unit shall be galvanized steel with a baked on powder coated finish on all panels except unit base

#### **Heat Exchangers**

Evaporator coil shall be mechanically bonded Aluminum fin to copper tube. Fins shall be coated to resist corrosion

The Refrigerant to Water HX (Gas Cooler) shall be a Double Wall co-axial type pressure tested to 6000 psi

#### Refrigerant System

Compressor shall be a hermetically sealed DC Inverter drive Rotary type. Refrigerant shall be R744 (CO<sub>2</sub>). Refrigerant flow shall be controlled by an Electronic Expansion Valve

#### Fan & Motor

The outdoor unit fan shall be a propeller type, driven by a BLDC Motor

#### **Water Pump**

The pump shall be a BLDC Impellor type, with a maximum lift of 23ft and total piping length of 66ft

#### **Controls**

The unit shall be operated using Eco2 Systems supplied Temperature sensor(s) installed in the Storage tank Tank Temperature Sensor part number is 91101-45190. The SAN-43, SAN-83, SAN-119, ECO-119 & ECO-200 Tanks shall have Temp sensor(s) factory installed. The sensor(s) installed in the Tank shall be wired directly to the GS4 Heat Pump(s). Control wiring to each Heat Pump shall require 18AWG stranded, shielded wire

#### Interconnect Piping

Interconnect Piping shall be 1/2" copper or where permitted 1/2" PEX tubing directly to the Heat Pump(s) More than 2 Heat Pumps connected to the same tank shall utilize a reverse return manifold piping system Both Cold and Hot piping should be insulated with min 3/4" closed cell foam and where required Heat Trace shall be used to prevent pipes from freezing

ECO2 Systems LLC

PO Box 1358, Walled Lake MI 48390, Tel: 1-844 SAND CO2 (1-844 726 3262)





# **SUBMITTAL : GS4-45HPC Heat Pump Water Heater**



Job Name	Location
Purchaser	Engineer
Submitted to	Reference Approval Construction
Unit Designation	Schedule #

### **GS4-45HPC Dimensions**





Unit∶inch

Eco2 Systems LLC

PO Box 1358, Walled Lake MI 48390, Tel : 1-844 SAND CO2 (1-844 726 3262) www.eco2waterheater.com